



The State of New Hampshire  
**DEPARTMENT OF ENVIRONMENTAL SERVICES**

RECEIVED  
 FEB 26 2019



**Robert R. Scott, Commissioner**

**Owner/Responsible Party:**  
 DIANE CUNNINGHAM  
 EMERALD LAKE VILLAGE  
 DISTRICT  
 PO BOX 2217  
 HILLSBOROUGH, NH 03244

**NOTICE OF SECONDARY  
 FLUORIDE EXCEEDANCE  
 Immediate Action Required**

**Public Water System:**  
 EMERALD LAKE  
**PWS ID:** 1141020  
**Location:** HILLSBOROUGH

**Date Issued:** February 21, 2019

Department of Environmental Services (“DES”) records indicate the water samples results submitted for fluoride, collected within the last three years as specified below, exceeds the secondary maximum contaminant level (“SMCL”) of 2.0 mg/L:

**Fluoride Average for 2018:** 3.0 mg/L      **SMCL:** 2.0 mg/L  
**Sampling Site ID:** 512 - MEETING HSE DEP TAP/AF TRT/BLD 004 111

Pursuant to Env-Dw 803.01, the owner of a public water system that exceeds the SMCL for fluoride is required to perform public notice on an annual basis.

**Required Actions**

Action	When	Rule Citation
1. Perform Public Notice	Within 30 days of the date of the notice	Env-Dw 801
2. Certify that public notice was performed	Within 10 days of performing public notice	Env-Dw 801

Please be advised that pursuant to RSA 485, failure to perform public notice will result in additional enforcement action against the owner of the water system. If you have already provided public notice to your customers, please forward a copy to us and our records will be modified accordingly. Community systems may either follow the above procedure, or include the public notice in their annual Consumer Confidence Report (“CCR”), which must be delivered to consumers and DES by July 1 of each year. A community system choosing to include the notice in its CCR must note their intention within 10 days by checking the appropriate box on the public notice template and returning a copy to our department.

Public Notice Forms can be found online at: [www.des.nh.gov](http://www.des.nh.gov); click on A to Z list and select Public Notice (for Public Water Systems). The appropriate template for the Water System’s violation is under the “Chemical” heading, entitled “Fluoride Secondary MCL violation”.

Please contact me if you have any questions.

Issued by:

Tricia Madore  
 Tricia.Madore@des.nh.gov  
 (603) 271-3907  
 Drinking Water and Groundwater Bureau

cc: File  
 Town of HILLSBOROUGH, Health Officer  
 JOSEPH DAMOUR, Primary Operator